

the population, including its distribution, and of the regional environs, including its historical and esthetic values.

(f) The facility must be sited so as to avoid to the extent possible the long-term and short-term adverse impacts associated with the occupancy and modification of floodplains.

§ 72.92 Design basis external natural events.

(a) Natural phenomena that may exist or that can occur in the region of a proposed site must be identified and assessed according to their potential effects on the safe operation of the ISFSI or MRS. The important natural phenomena that affect the ISFSI or MRS design must be identified.

(b) Records of the occurrence and severity of those important natural phenomena must be collected for the region and evaluated for reliability, accuracy, and completeness. The applicant shall retain these records until the license is issued.

(c) Appropriate methods must be adopted for evaluating the design basis external natural events based on the characteristics of the region and the current state of knowledge about such events.

§ 72.94 Design basis external man-induced events.

(a) The region must be examined for both past and present man-made facilities and activities that might endanger the proposed ISFSI or MRS. The important potential man-induced events that affect the ISFSI or MRS design must be identified.

(b) Information concerning the potential occurrence and severity of such events must be collected and evaluated for reliability, accuracy, and completeness.

(c) Appropriate methods must be adopted for evaluating the design basis external man-induced events, based on the current state of knowledge about such events.

§ 72.96 Siting limitations.

(a) An ISFSI which is owned and operated by DOE must not be located at any site within which there is a candidate site for a HLW repository. This

limitation shall apply until such time as DOE decides that such candidate site is no longer a candidate site under consideration for development as a HLW repository.

(b) An MRS must not be sited in any State in which there is located any site approved for site characterization for a HLW repository. This limitation shall apply until such time as DOE decides that the candidate site is no longer a candidate site under consideration for development as a repository. This limitation shall continue to apply to any site selected for construction as a repository.

(c) If an MRS is located, or is planned to be located, within 50 miles of the first HLW repository, any Commission decision approving the first HLW repository application must limit the quantity of spent fuel or high-level radioactive waste that may be stored. This limitation shall prohibit the storage of a quantity of spent fuel containing in excess of 70,000 metric tons of heavy metal, or a quantity of solidified high-level radioactive waste resulting from the reprocessing of such a quantity of spent fuel, in both the repository and the MRS until such time as a second repository is in operation.

(d) An MRS authorized by section 142(b) of NWPA (101 Stat. 1330-232, 42 U.S.C. 10162(b)) may not be constructed in the State of Nevada. The quantity of spent nuclear fuel or high-level radioactive waste that may be stored at an MRS authorized by section 142(b) of NWPA shall be subject to the limitations in § 72.44(g) of this part instead of the limitations in paragraph (c) of this section.

§ 72.98 Identifying regions around an ISFSI or MRS site.

(a) The regional extent of external phenomena, man-made or natural, that are used as a basis for the design of the ISFSI or MRS must be identified.

(b) The potential regional impact due to the construction, operation or decommissioning of the ISFSI or MRS must be identified. The extent of regional impacts must be determined on the basis of potential measurable effects on the population or the environment from ISFSI or MRS activities.